




ADDENDUM #1

Issued: February 13, 2015

Project #: COLG15-PROJ-1

City of Locust Grove – Tanger Station Ballfields FENCING

Issued by:  _____, Bert Foster, Director

The following items take precedence over referenced portions of the document for the above-named project and in executing a contract, will become part thereof.

Where any item in the document is supplemented hereby, the original requirements will remain in effect.

All supplemental conditions will be considered as added thereto.

Where any original item is amended, voided or superseded hereby, the provisions of such items not so specifically amended, voided or superseded will remain in effect.

1. 2.4 Components B - Corner and terminal posts are stated as 3.5 inch. Typical posts are 3" for available hardware.

3" is allowable, Schedule 40 posts required, as stated.

2. 2.4 Components C - Gate post are stated as 4 inch. Typical posts are 3" for available hardware.

3" is allowable, Schedule 40 posts required, as stated.

3. 2.4 Components E - Foul Poles are stated as 6.63 inch. Typical foul poles are 4"

Foul Poles to be 4" schedule 40 at 25' above finished grade.

4. 2.4 F - On what height fence are intermediate rails used?

Intermediate rails are shown on details as required. See photos of backstop: 3' back, 8' on side

5. 3.1 B - Raised concrete around the posts can cause a trip hazard.

Please verify if the post footing is to be exposed or below grade

Concrete to be below grade.

6. 3.1 F - Please verify that the rail sleeves are 6" (Typical)

Rail sleeves are per specification.

7. 3.1 H - Fence fabric typically faces the field side of the fence, please verify which side the fabric should be installed on.

Fence fabric should be on the field side and the exterior side of the dugouts.

8. NOTE: Backstop posts can be 4' diameter instead of 6"

CONTINUED ON NEXT PAGE

You must acknowledge receipt of this addendum (#1) on your final bid proposal, which is due Friday (2/20/15 by 11AM), in order to be considered for the work.
Failure to acknowledge this addendum may result in a non-responsive bid.